

Pleasant Valley School District
Workplace Safety Committee

Building Inspection Form

Science Labs

School: _____

Date: _____

Location: _____

Completed by: _____

1. Personal protective equipment is available, in good condition and used (e.g. face shields, safety glasses, aprons, gloves, respirators.) YES NO Date of Action _____

Comment: _____

2. Eye wash and deluge showers are near chemical handling areas. YES NO Date of Action _____

Comment: _____

3. Portable fire extinguishers are either carbon dioxide, dry chemical or halogenated agent types. YES NO Date of Action _____

Comment: _____

4. Portable fire extinguishers are within 30 feet of all occupants. YES NO Date of Action _____

Comment: _____

5. All laboratories have a fire alarm system which alerts all building occupants and the local fire department. YES NO Date of Action _____

Comment: _____

6. Non-combustible fume hoods are provided. YES NO Date of Action _____

Comment: _____

7. Chemical stockroom: YES NO Date of Action _____

✓ Ventilation to the outside YES NO Date of Action _____

✓ Not crowded, good housekeeping YES NO Date of Action _____

✓ All containers are labeled: toxicity, flammability, reactivity, date received, disposal date YES NO Date of Action _____

✓ Not used as a preparation area YES NO Date of Action _____

✓ Access is limited / controlled YES NO Date of Action _____

✓ Spill trays are used YES NO Date of Action _____

✓ Room construction would stop fire spread YES NO Date of Action _____

✓ Incompatible or reactive chemicals are separated YES NO Date of Action _____

✓ Unbreakable containers are used YES NO Date of Action _____

✓ HAZCOM: _____ MSDS Books YES NO Date of Action _____

Comment: _____

Safety is No Accident

